Lead and Copper Consumer Notice Drinking Water Sample Results Table

(Sa e Drinking Water Act, 1976 PA 399, as amended)

The table below lists the m st ecent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name: GOODWILLIE ENVIRONMENTAL SCHOOL WSSN: 2089341

Sample Number	Sample Location		Sample Date	Analyte Code	Results *	Comment
Samples related to Source #	001				illiligrams / liter	
PNC06041943939	Drinking Fountain	SDF-102	6/4/2019	Lead	0	
PNC06041943939	Drinking Fountain	SDF-102	6/4/2019	Copper	0.135	
PNC06041944812	Drinking Fountain	LOW DF @ CAFETER	R 6/4/2019	Lead	0	
PNC06041944812	Drinking Fountain	LOW DF @ CAFETER	R 6/4/2019	Copper	0.119	
PNC06041952266	Drinking Fountain	SDF-103	6/4/2019	Lead	0	
PNC06041952266	Drinking Fountain	SDF-103	6/4/2019	Copper	0.125	
PNC06041991624	Drinking Fountain	SDF-101	6/4/2019	Lead	0	
PNC06041991624	Drinking Fountain	SDF-101	6/4/2019	Copper	0.143	
PNC06041994692	Drinking Fountain	SDF-104	6/4/2019	Lead	0	
PNC06041994692	Drinking Fountain	SDF-104	6/4/2019	Copper	0.121	

For informa in on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at www.epa.gov/lead, or contact your health care provider.

^{*} All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.